

VATAMAN TRANSMISSION LIMITED
(100% wholly owned subsidiary of Power Grid Corporation of India Limited)
B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI,
NEW DELHI-110 016

NOTICE
(UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)

1. **VATAMAN TRANSMISSION LIMITED**, having its Registered Office at **B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI-110016**, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under Sub- Section (1) of Section 15 of the Electricity Act, 2003 for grant of Transmission Licence in respect of the transmission lines, sub-stations and other assets, the details of which are given below:-

Sl. No.	Name of the Line / Substation (location)	Line Length * /Capacity	Annual Transmission Charges (INR) Million per annum	Commissioning Schedule	Remarks
1.	<p>Establishment of 765 kV switching station near Vataman with 2x330MVA, 765 kV bus reactor</p> <ul style="list-style-type: none"> • 330 MVAR 765 kV bus reactor-2 (7x110 MVA single phase reactor units including 1 spare unit for line/bus reactor) • 765 kV bus reactor bays- 2 • 765 kV line bays- 8 (for lines at Sl. 2, 5 & 7) <p>Future Scope: Space for</p> <ul style="list-style-type: none"> • 765/400kV ICT along with bays- 6 Nos. • 765 kV line bays along with switchable line reactors – 6 Nos • 765kV Bus Reactor along with bay: 2 Nos. • 765kV Sectionalizer bay: 1 -set • 400 kV line bays along with switchable line reactor – 12 Nos. • 400/220kV ICT along with bays -8 Nos. • 400 kV Bus Reactor along with bay: 		4018.15	24 Months from Effective Date	



	<p>2 Nos.</p> <ul style="list-style-type: none"> • 400kV Sectionalization bay: 1- set • 220 kV line bays: 16 Nos. • 220kV Sectionalization bay: 2 sets • 220kV BC and TBC: 3 Nos. • STATCOM (± 300 MVar) along with MSC (2x125 MVar) & MSR (1x125 MVar) alongwith associated bays: 1 No. 				
2.	Halvad – Vataman 765 kV D/c line	129.559 Km			
3.	<p>1x330 MVar switchable line reactor on each ckt. at Vataman end of Halvad – Vataman 765 kV D/c line.</p> <ul style="list-style-type: none"> • 330 MVar, 765 kV switchable line reactor- 2 Nos. (6 x 110 MVar single phase reactor unit) [110 MVar single phase spare bus reactor unit to be used as spare for line reactor] • Switching equipment for 765 kV line reactors- 2 				
4.	<p>2 nos. of 765 kV line bays at Halvad end for termination of Halvad – Vataman 765 kV D/c line</p> <ul style="list-style-type: none"> • 765 kV line bays– 2 Nos. (for Halvad end) 				
5.	LILO of Lakadia – Vadodara 765 kV D/c line at Vataman 765 kV switching station	39.521 Km			
6.	<p>240 MVar 765 kV switchable line reactor on each ckt at Vataman end of Lakadia – Vataman 765 kV D/c line with NGR bypassing arrangement</p> <ul style="list-style-type: none"> • 240 MVar, 765 kV switchable line reactor- 2 (7x 80 MVar single phase reactor unit including 1 spare unit) • Switching equipment for 765 kV line reactors- 2 				
7.	Vataman switching station – Navsari (New)(GIS) 765 kV D/c line	257.713 Km			
8.	<p>330 MVar switchable line reactors on each ckt at Navsari (New) (GIS) end of Vataman switching station – Navsari (New) (GIS) 765 kV D/c line</p> <ul style="list-style-type: none"> • 330 MVar, 765 kV switchable line reactor- 2 Nos. (6x 110 MVar single 				



	phase reactor unit) [110 MVA spare reactor unit at Navsari being implemented by PGCIL, would be used as spare] • Switching equipments for 765 kV line reactor- 2				
9.	2 Nos. of 765 kV GIS line bays at Navsari (New) for termination of Vataman switching station – Navsari (New)(GIS) 765 kV D/c line • 765 kV line bays (GIS) – 2 Nos. (2 Nos. for Navsari (New) end)				

*as per survey report furnished by Bid Process Coordinator

**Effective Date: 26.12.2023

2. Complete application and other documents filed before the Commission are available on the web site of Power Grid Corporation of India Limited <https://www.powergrid.in/subsidiaries> for access by any person. The application can also be inspected at the office of the Company at C/o ED (TBCB), Power Grid Corporation of India Limited, Saudamini, Plot No.2, Sector -29, Gurgaon 122001 with Sh. Ram Rekha Yadav, Project Incharge, Vataman Transmission Limited or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd Floor, Chanderlok Building, Janpath, New Delhi -110 001, with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 30 days of the publication of the notice on the website of POWERGRID.



Ram Rekha Yadav,
Project In-charge,
Vataman Transmission Limited

Place: New Delhi

Date: 26/12/2023

