

**BEAWAR DAUSA TRANSMISSION LIMITED**  
**(100% wholly owned subsidiary of Power Grid Corporation of India Limited)**  
**B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI,**  
**NEW DELHI-110 016**

**NOTICE**

**(UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003)**

1. **BEAWAR DAUSA TRANSMISSION LIMITED**, having its Registered Office at **B-9, QUTAB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI-110016**, which is incorporated under the Companies Act, 2013, has made an application before the Central Electricity Regulatory Commission, New Delhi under Sub- Section (1) of Section 15 of the Electricity Act, 2003 for grant of Transmission Licence in respect of the transmission lines, sub-stations and other assets, the details of which are given below:-

Sl. No.	Name of the Line / Substation (location)	Line Length* /Capacity	Annual Transmission Charges (INR) Million per annum	Commissioning Schedule	Remarks
1.	Establishment of 2x1500 MVA 765/400kV substation at suitable location near Dausa along with 2x330 MVA, 765 kV Bus Reactor & 2x125 MVA, 420 kV bus Reactor 765/400kV 1500 MVA ICTs: 2 nos. (7x500 MVA, including one spare unit) 330 MVA, 765 kV bus reactors: 2 nos. (7x110 MVA, including one spare unit) 765kV ICT bays – 2 nos 400 kV ICT bays – 2 nos. 765 kV line bays – 6 nos. 400kV line bay- 4 nos. 765kV reactor bay- 2 nos. 125 MVA, 420kV bus reactor – 2 nos. 420 kV reactor bay – 2 nos. Future provisions: Space for 765/400kV ICTs along with bays: 2 nos. 765kV line bay along with switchable line reactor: 4 nos. 765kV Bus Reactor along with	2x1500 MVA 765/400kV	2002.84	18 Months from Effective Date	



*[Handwritten signature]*


	bays: 2 nos. 400/220 kV ICTs along with bays: 2 nos. 400 kV line bays along with switchable line reactor: 4 nos. 400kV Bus Reactor along with bays: 1 no. 220 kV line bays: 4 nos.				
2.	LILO of both circuits of Jaipur (Phagi)-Gwalior 765 kV D/c at Dausa along with 240 MVAR Switchable line reactor for each circuit at Dausa end of Dausa – Gwalior 765 kV D/c line Switching equipment for 765 kV 240MVAR switchable line reactors - 2 nos. 240 MVAR 765 kV Switchable line reactors - 2 nos. (7x80 MVAR considering one spare unit) (also to be used as spare reactor at Dausa end for 765kV Beawar – Dausa D/c line)	75.32 km			
3.	LILO of both circuits of Agra – Jaipur(south) 400kV D/c at Dausa along with 50 MVAR Switchable line reactor for each circuit at Dausa end of Dausa – Agra 400kV D/c line. Switching equipment for 420kV, 50MVAR switchable line reactor –2 420kV, 50MVAR Switchable line reactor-2 nos.	10.91 km			
4.	Beawar – Dausa 765 kV D/c line along with 240 MVAR Switchable line reactor for each circuit at each end Switching equipment for 765kV 240MVAR switchable line reactor –4 765kV, 240MVAR Switchable line reactor- 4 nos	263.80 km			
5.	2 nos. of 765kV line bays at Beawar for Beawar – Dausa 765 kV D/c line 765kV line bays – 2 nos				



\*as per survey report furnished by Bid Process Coordinator

\*\*Effective Date: 30.10.2023

2. Complete application and other documents filed before the Commission are available on the web site of Power Grid Corporation of India Limited <https://www.powergrid.in/subsidiaries> for access by any person. The application can also be inspected at the office of the Company at C/o ED (TBCB), Power Grid Corporation of India Limited, Saudamini, Plot No.2, Sector -29, Gurgaon 122001 with Sh. Ramesh Kumar, Project Incharge, Beawar Dausa Transmission Limited or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections or suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3<sup>rd</sup> Floor, Chanderlok Building, Janpath, New Delhi -110 001, with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent, within 30 days of the publication of the notice on the website of POWERGRID.



Ramesh Kumar,  
Project Incharge,  
Beawar Dausa Transmission Limited

Place: New Delhi

Date: 30/10/2023

